



Tinytag View 2 Current Logger (0 to 200A AC)

TV-4810

Issue 3 21st April 2011 E&OE



The TV-4810 measures current from 0 to 200A AC and is ideal for mains and power consumption monitoring.

As well as recording data the unit has a display that shows what the unit is currently reading. The unit has an IP65 case and features high reading resolution and accuracy, a large memory, a fast offload speed and a low battery monitor.

This unit is supplied with a current clamp suitable for conductor sizes up to 20mm.

Popular Applications

- Mains Monitoring
- Power Consumption Monitoring

Features

- 0 to 200A AC Current data logger
- LCD display of current readings
- 30,000 reading capacity
- High Accuracy
- High Reading Resolution
- Fast Data Offload
- 2 user-programmable alarms
- Low battery monitor
- User-replaceable battery





UK / Europe Office Tel +44 (0)845 9000 601 Fax +44 (0)845 9000 602 info@omni.uk.com www.omniinstruments.co.uk Australia / Asia Pacific Office Tel +61 (0)282 442 363 Fax +61 (0)294 751 278 info@omniinstruments.com.au www.omniinstruments.com.au USA / Canada Office Tel +1-866-849-3441 Fax +1-866-628-8055 info@omniinstruments.net www.omniinstruments.net



Tinytag View 2 Current Logger (0 to 200A AC) TV-4810

Issue 3 : 21st April 2011 (E&OE)



Features

 Total Reading Capacity
 30,000 readings

 Memory type
 Non Volatile

 Display
 4 digits + indicat

 Display Refresh Rate
 Every 2 seconds

 Trigger Start
 Magnetic Switch

 Delayed Start
 Relative / Absolu

 (up to 45 days)

Stop Options

Reading Types Logging Interval Offload

Alarms

	Non Volatile
	4 digits + indicators
Rate	Every 2 seconds
	Magnetic Switch
	Relative / Absolute
	(up to 45 days)
	When full
	After n Readings
	Never (overwrite oldest data)
	Actual, Min, Max
	1 sec to 10 days
	While stopped or when
	logging in minutes
	mode
	2 fully programmable; latchable
	, p

Reading Specification

Reading Range Frequency Range Maximum Current Reading Resolution Display Resolution Accuracy 0.15 to 200A AC 40Hz to 10kHz 240A AC* 10mA 0.1A 0.5A to 10A (5% of reading +/-0.5A) 10A to 40A (3% of reading +/-0.5A) 40A to 200A (2% of reading +/-0.5A)

*The measuring time between 200 and 240A should be limited to 10 minutes on, followed by 30 minutes off.

Physical Specification

Data Logger (TV-4810)

Operational Range* Case Dimensions	-30℃ to +70℃
Diameter	60mm / 2.36"
Length	85mm / 3.35"
Width	77mm / 3.03"
Depth	35mm / 1.38"
Weight	85g / 3oz

*The Operational Range stated above indicates the physical limits to which the unit can be exposed.

Current Clamp (ACS-0003)

Operational Range** Clamp Dimensions	-10 ℃ to +55 ℃ (14 ℉ to +131 ℉)
Length	135mm / 5.31"
Width	35mm / 1.38"
Height	65mm / 2.56"
Weight	180g / 6.35oz
Lead Length	1.5m
Conductor Size	20mm (maximum)

**The Operational Range stated above indicates the physical limits to which the clamp can be exposed.

Notes

Battery Type

Tekcell SBAA02P; SAFT LS14250 or LST14250

The logger will operate with other ½AA 3.6V Lithium (Li-SOCI2) batteries but performance cannot be guaranteed.

Replacement Interval Annually

Before replacing the battery the data logger must be stopped.

Data stored on the logger will be retained after a battery is replaced.

The clarity of the display may change at extremes of temperature.

If used at low temperatures the data logger should be allowed to warm to room temperature before it is opened to avoid condensation forming inside the unit.

Calibration

This unit is configured to meet Gemini's quoted accuracy specification during its manufacture.

We recommend that the calibration of this unit should be checked annually against a calibrated reference meter.

A UKAS traceable certificate of calibration can be supplied for an additional charge either at the point of purchase, or if the unit is returned for a Service Calibration.

Approvals

This equipment complies with part 15 of the FCC rules. Operation is subject to the following two conditions: (1) this device may not cause any harmful interference, and (2) the device must accept any interference received, including interference that may cause undesired operation.

Gemini Data Loggers (UK) Ltd. operates Quality and Environmental Management Systems which conform to ISO 9001 and ISO 14001. The scope of these systems covers the design, manufacture and servicing of data logging and associated equipment, including software.



Required and Related Products

To use this data logger you will also require one of the following pieces of software:

SWCD-0040: Tinytag Explorer software or SW-0500: Easyview Pro software

and a

CAB-0007-USB: Tinytag Ultra/Plus/View USB Download Cable

Further related products:

CAB-0007: Tinytag Ultra/Plus/View Serial Download Cable SER-9500: Tinytag Data Logger Service Kit ACS-5000: Tinytag Alarm Box ACS-6000: Trigger Start Magnet



ata sheet

UK / Europe Office Tel +44 (0)845 9000 601 Fax +44 (0)845 9000 602 info@omni.uk.com www.omniinstruments.co.uk Australia / Asia Pacific Office Tel +61 (0)282 442 363 Fax +61 (0)294 751 278 info@omniinstruments.com.au www.omniinstruments.com.au

USA / Canada Office Tel +1-866-849-3441 Fax +1-866-628-8055 info@omniinstruments.net www.omniinstruments.net